



## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

### Total Trihalomethanes (TTHM) MCL Violation at PWS AZ0407094

Our water system recently violated a drinking water standard. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did (are doing) to correct this situation.

We routinely monitor the presence of drinking water contaminants. Testing results from 4/16/2026 show that our system exceeds the standard, or maximum contaminant level (MCL), for TTHM. The standard for TTHM is 0.080 mg/L. It is determined by averaging all the samples collected at each sampling location for the most recent four quarters of the year. The average level of TTHM over the four quarters at two locations was 0.084 mg/L and 0.081 mg/L.

#### What should I do?

- There is nothing you need to do. You do not need to boil your water or take other corrective actions. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

#### What does this mean?

This is not an emergency. If it had been an emergency, you would have been notified within 24 hours. TTHM are four volatile organic chemicals which form when disinfectants react with natural organic matter in the water.

*\*People who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer. \**

#### What is being done?

Lower the chlorine residual and maintain a concentration of 1.0 -1.20 ppm leaving the reservoir. Verify the reservoir mixers and blower system are operating with design standards. Within the distribution system, verify the auto-flushers are operating and provide additional flushing within the immediate community. We anticipate resolving the problem within the next required reporting period.

For more information, please contact Mark Ortiz at [mark.ortiz@goodyearaz.gov](mailto:mark.ortiz@goodyearaz.gov).

*\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. \**

This notice is being sent to you by City of Goodyear. State Water System ID#: AZ0407094.  
Date distributed:05/18/2026 and 05/28/2026